Emergency Eyewash Inspection Record

Emergency eyewashes must be activated monthly. Activations include running water through the equipment for 10 seconds or longer if necessary and verifying that equipment is intact and in working order. These activations must be documented.

Inspectors Initials	Date (Month/Year)	Comments/Notes