
From: [REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]

Sent: Fri Feb 19 17:19:03 2010
Subject: Bingham Facility Update - Feb. 19

Friends and Neighbors:

We informed you on Wednesday of our plan to suspend the wastewater treatment system operation at the Bingham Facility when we receive permission to pump and haul the wastewater from the site. We applied for the pump and haul permit today and expect an answer soon.

In keeping with our pledge to keep you up to date on matters at Bingham, I wanted to let you know that, on yesterday, operators at the facility initiated spray operations of the permitted wastewater treatment system. Water was observed bubbling out of the ground near the pump house and operators identified a damaged pipe leading from the pump house to the spray field.

DENR was initially notified on yesterday and formally notified by letter (attached) today.

We look forward to discussing the issues involving the Bingham Facility with you at next Tuesday's Town Hall meeting.

Regards,
Dwayne

Dwayne Pinkney

Special Assistant to the Chancellor

for State and Local Relations and

AVC for Enterprise Services

University of North Carolina at Chapel Hill

CB# 1000

Chapel Hill, North Carolina 27599-1000

Phone) 919-962-0711 Fax) 919-962-0647