



Steven W. Troxler
Commissioner

North Carolina Department of Agriculture
and Consumer Services
Standards Division

Stephen Benjamin
Director

July 20, 2011

UNC-CH Environmental, Health & Safety
Attention: Mary Beth Koza, Director
1120 Estes Drive Extension, CB# 1650
Chapel Hill, NC 27599

This approval concerns the application you made for the LP-Gas tanks at: Bingham Facility, Bingham, NC.

The enclosed drawing, stamped for approval, is your record of this site being approved for installation of LP-Gas tank(s) as shown on the drawing. If the tank will be installed other than as shown, you must contact this office prior to installation for approval of the modification.

Approvals are good for one year. If the site is not developed as shown on the drawing within one year of the date shown above, this approval is revoked. However, the approval is not revoked if fewer tanks than shown on the drawing are installed. After one year, no other tanks may be installed unless drawings are resubmitted.

Be aware that the conclusions of the fire safety analysis or of the meeting with local fire officials may require special fire protection measures. This approval does not override those requirements, which must be provided within 60 days of the container installation. Local permits may also be required for this installation. The owner/operator is responsible for determining that the soil has sufficient bearing strength for this installation and the installer should verify that this has been done. Written operating and maintenance procedures must be available for inspection *prior to startup* of installation.


COPIES RECEIVED	COPIES RETURNED	DATE	SITE NUMBER	DESCRIPTION
4	2	7/20/2011	2490	Two 18,000-gallon propane tanks

These are transmitted as checked below:

- Approved As Submitted
- Approved As Modified
- Approved As Noted

REMARKS:

COPY TO: Wayne Joyce


Richard G. Fredenburg
LP-Gas Engineer